

Drinking Water Quality and Compliance Village of Marengo

Introduction

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the Marengo water quality and sample submission compliance record for the January 1st to December 31st, 2024 time period. This report was completed on June 27th, 2025 Readers should refer to Water Security Agency's [Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502](#) for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html.

Water Quality Standards

Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL	24	26	0
E. coli	0 Organisms/100 mL	24	26	0
Background Bacteria	Less than 200/100 mL			

Water Disinfection –

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.78 to 2.21	0.32 to 1.57	24	26	100

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records- From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.06 to 3.07	365	1

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit Limit (NTU)	Range (NTU) Range (NTU)	# Tests Required	#Tests Performed	# of Days Exceeding Limit
Turbidity	<0.3 or 0.2 95% of Measurements each month; not to exceed 0.3 or 0.2 for more than 12 consecutive hours Never > 1.0	0.02 to 0.198	365	365	0

Inline Turbidity meter started June 16, 2021



**Saskatchewan
Ministry of
Environment**



Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on August 28th, 2023. Sample results indicated that the provincial drinking water quality standards were not exceeded. Monthly manganese samples are being completed to track any variance in readings.

Parameter	Limit MAC(mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit	
Arsenic	0.010		0.0005	0	* Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.
Barium	1.0		0.0663	0	
Boron		5.0	0.1	0	
Cadmium	0.005		0.00015	0	
Chromium	0.05		0.00019	0	
Fluoride (avg*)	1.5		0.25	0	
Lead	0.01		0.0001	0	
Manganese	0.05		0.01/monthly (0.0044 in Dec 2024)	0	
Nitrate (avg*)	45		0.8	0	
Selenium	0.01		0.00113	0	
Uranium	0.02		0.0078	0	

Chemical – Trihalomethanes (THMs) and Haloacetic Acids (HAAs)

Parameter	THMs Limit (mg/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Trihalomethanes	0.1	0.086	4 (1 every 3 months)	4
Haloacetic Acids	0.08	0.028	4 (1 every 3 months)	4

General Chemical

Parameter	Aesthetic Objectives * (mg/L)	Sample Results (average)	# Samples Required	# Samples Submitted
Alkalinity	500	332	1	1
Bicarbonate	No Objective	405	1	1
Calcium	No Objective	147	1	1
Carbonate	No Objective	0	1	1
Chloride	250	46.6	1	1
Conductivity	No Objective	1462	1	1
Hardness	800	668	1	1
Magnesium	200	73	1	1
PH	No Objective	7.7	1	1
Sodium	300	110	1	1
Sulphate	500	433.3	1	1
Total dissolved Solids	1500	1228	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids.

The sample for General Chemical analysis required in 2023 was submitted on August 28th, 2023. Sample results indicated that there were no exceedences of the provincial aesthetic objectives for the General Chemical category.

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazard. The aesthetic objectives for several parameters (including



**Saskatchewan
Ministry of
Environment**



hardness as CaCO₃, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on water quality and sample submission performance may be obtained from:

Village of Marengo
Box 70 Marengo, SK S0L 2K0
306-968-2922/Fax: 306-912-8922
rm292.rm322@sasktel.net



**Saskatchewan
Ministry of
Environment**

